



2026 FIVE YEAR MOVING AVERAGE STATUSREPORT

August, 2026

MEMBER	Fractional Share of the Contribution ("Percent Share")						5 Year Moving Average	
	MEASURING YEAR (Oct-Sep)						Current Average (2)	Previous Average (3)
	2021	2022	2023	2024	2025	2026 (1)		
Clark	7.49%	7.88%	5.65%	5.19%	6.61%	8.29%	6.72%	6.56%
Cranford	11.79%	10.19%	10.24%	12.30%	9.12%	10.40%	10.45%	10.73%
Garwood	2.23%	3.19%	3.71%	2.66%	2.44%	2.51%	2.90%	2.85%
Kenilworth	3.59%	3.62%	3.77%	3.64%	3.41%	3.71%	3.63%	3.61%
Mountainside	2.35%	2.71%	2.66%	2.55%	2.97%	2.47%	2.67%	2.65%
Rahway	21.64%	17.77%	18.31%	19.66%	21.27%	19.04%	19.21%	19.73%
Roselle Park	1.73%	0.87%	1.24%	1.14%	1.35%	1.46%	1.21%	1.27%
Scotch Plains	3.86%	4.01%	4.40%	5.76%	6.11%	4.20%	4.90%	4.83%
Springfield	9.20%	10.34%	10.49%	10.22%	10.24%	9.12%	10.08%	10.10%
Westfield	14.46%	15.74%	14.96%	14.05%	13.05%	12.68%	14.10%	14.45%
Woodbridge	21.66%	23.68%	24.56%	22.83%	23.44%	26.12%	24.13%	23.23%
	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.01%

Notes:

- (1) Figures computed based on Flow, BOD and TSS data received as of reporting month.
- (2) Five year moving average consisting of 2022, 2023, 2024, 2025, and month to date for 2026
- (3) Five year moving average consisting of 2021, 2022, 2023, 2024, and 2025



2026 Town Annual Percent Share

August, 2026

Member	Average Daily Flow (MGD)		Biochemical Oxygen Demand (Tons/Day)		Total Suspended Solids (Tons/Day)		Annual Percent Share	
	2025	2026	2025	2026	2025	2026	2025	2026
Clark	1.30	1.83	1.33	2.02	1.32	2.18	6.61%	8.29%
Cranford	2.23	2.59	1.49	2.24	1.84	2.76	9.12%	10.40%
Garwood	0.57	0.61	0.41	0.55	0.50	0.67	2.44%	2.51%
Kenilworth	0.79	0.89	0.58	0.82	0.70	1.00	3.41%	3.71%
Mountainside	0.72	0.62	0.49	0.53	0.60	0.65	2.97%	2.47%
Rahway	4.79	4.49	3.71	4.23	4.38	5.19	21.27%	19.04%
Roselle Park	0.32	0.35	0.22	0.32	0.28	0.40	1.35%	1.46%
Scotch Plains	1.47	1.05	1.01	0.90	1.24	1.12	6.11%	4.20%
Springfield	2.39	2.21	1.73	2.00	2.10	2.45	10.24%	9.12%
Westfield	2.85	2.91	2.30	2.88	2.74	3.47	13.05%	12.68%
Woodbridge (1)(2)	5.45	6.22	3.93	5.75	4.86	7.11	23.44%	26.12%
Totals:	22.88	23.77	17.20	22.24	20.56	27.00	100.00%	100.00%

Equations:

Assumptions: 200 gpd flow per unit at 200 mg/L BOD and TSS concentrations

(a) Flow Adj: [Total Adjusted Dwelling Units] x (0.0002 MGD)

(b) BOD Adj: [Total Adjusted Dwelling Units] x (0.0002 MGD) x (200 mg/L) x (8.34 lbs/g) / (2000 lbs/ton)

(c) TSS Adj: [Total Adjusted Dwelling Units] x (0.0002 MGD) x (200 mg/L) x (8.34 lbs/g) / (2000 lbs/ton)

Notes:

(1) Woodbridge MGD Adjustment includes a 0.50 MGD flow credit, per section 11.5 of the 2021 Agreement

(2) Woodbridge BOD and TSS Adjustment includes a 833 lbs/day credit, per section 11.5 of the 2021 Agreement



2026 Intermunicipal Adjustments Report

August, 2026

Member	Dwelling Unit Quantity			Average Daily Flow (MGD)			Average BOD (Tons/Day)			Average TSS (Tons/Day)		
	Bill To	Credit To	Total Adjustment	Average Flow	Adjustment (a)	Final Flow	Average BOD	Adjustment (b)	Final BOD	Average TSS	Adjustment (c)	Final TSS
Clark	479	0	479	1.73	0.0958	1.83	1.94	0.0799	2.02	2.10	0.0799	2.18
Cranford	242	1,092	-850	2.76	-0.1700	2.59	2.38	-0.1418	2.24	2.90	-0.1418	2.76
Garwood	54	110	-56	0.62	-0.0112	0.61	0.56	-0.0093	0.55	0.68	-0.0093	0.67
Kenilworth	62	38	24	0.89	0.0048	0.89	0.82	0.0040	0.82	1.00	0.0040	1.00
Mountainside	106	339	-233	0.67	-0.0466	0.62	0.57	-0.0389	0.53	0.69	-0.0389	0.65
Rahway	13	15	-2	4.49	-0.0004	4.49	4.23	-0.0003	4.23	5.19	-0.0003	5.19
Roselle Park	38	117	-79	0.37	-0.0158	0.35	0.33	-0.0132	0.32	0.41	-0.0132	0.40
Scotch Plains	66	413	-347	1.12	-0.0694	1.05	0.96	-0.0579	0.90	1.18	-0.0579	1.12
Springfield	0	187	-187	2.25	-0.0374	2.21	2.03	-0.0312	2.00	2.48	-0.0312	2.45
Westfield	1,425	175	1,250	2.66	0.2500	2.91	2.67	0.2085	2.88	3.26	0.2085	3.47
Woodbridge (1)(2)	10	9	1	6.72	-0.4998	6.22	6.17	-0.4163	5.75	7.53	-0.4163	7.11
Totals:	2,495	2,495	0	24.27	-0.5000	23.77	22.66	-0.4165	22.24	27.42	-0.4165	27.00

Equations:

Assumptions: 200 gpd flow per unit at 200 mg/L BOD and TSS concentrations

(a) Flow Adj: [Total Adjusted Dwelling Units] x (0.0002 MGD)

(b) BOD Adj: [Total Adjusted Dwelling Units] x (0.0002 MGD) x (200 mg/L) x (8.34 lbs/g) / (2000 lbs/ton)

(c) TSS Adj: [Total Adjusted Dwelling Units] x (0.0002 MGD) x (200 mg/L) x (8.34 lbs/g) / (2000 lbs/ton)

Notes:

(1) Woodbridge MGD Adjustment includes a 0.50 MGD flow credit, per section 11.5 of the 2021 Agreement

(2) Woodbridge BOD and TSS Adjustment includes a 833 lbs/day credit, per section 11.5 of the 2021 Agreement



Member BOD and TSS Loading Contribution

August, 2026

Member	Average Daily Industrial Loading (1)		Average Daily Flow (MGD)	Inter-Mun Adj (2) (MGD)	Adj. Avg. Daily Flow (MGD)	Member Contribution			
	BOD (Tons/Day)	TSS (Tons/Day)				Domestic Loading		Total Loading	
						BOD (Tons/Day)	TSS (Tons/Day)	BOD (Tons/Day)	TSS (Tons/Day)
Clark	0.26	0.05	1.73	0.1000	1.83	1.68	2.05	1.94	2.10
Cranford	0.00	0.00	2.76	-0.1700	2.59	2.38	2.90	2.38	2.90
Garwood	0.00	0.00	0.62	-0.0100	0.61	0.56	0.68	0.56	0.68
Kenilworth	0.00	0.00	0.89	0.0000	0.89	0.82	1.00	0.82	1.00
Mountainside	0.00	0.00	0.67	-0.0500	0.62	0.57	0.69	0.57	0.69
Rahway	0.11	0.16	4.49	0.0000	4.49	4.12	5.03	4.23	5.19
Roselle Park	0.01	0.02	0.37	-0.0200	0.35	0.32	0.39	0.33	0.41
Scotch Plains	0.00	0.00	1.12	-0.0700	1.05	0.96	1.18	0.96	1.18
Springfield	0.00	0.00	2.25	-0.0400	2.21	2.03	2.48	2.03	2.48
Westfield	0.00	0.00	2.66	0.2500	2.91	2.67	3.26	2.67	3.26
Woodbridge	0.00	0.00	6.72	0.0000	6.72	6.17	7.53	6.17	7.53
Totals:	0.38	0.23	24.27	-0.01	24.27	22.28	27.19	22.66	27.42

Notes:

- (1) As measured and reported by the RVSA SIU IPP Industrial Loading
- (2) Does not include the 0.50 MGD Woodbridge Credit



2026 Plant Influent Loading August, 2026

2025			2026									Average T/D
Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	

Plant Influent Flow and Sample Data

Avg. Daily Flow (MGD) (1)	19.65	19.94	23.5	22.48	28.99	36.84	24.55	22.97	20.21	22	26.12		24.30
Avg. BOD (mg/L) (2)	197	202	201	228	222	207	456	204	205	180	153		223
Avg. TSS (mg/L) (2)	238	228	228	256	237	228	623	304	237	224	181		271

Total Influent Loading (a)(b)

BOD (Tons/Day)	16.14	16.80	19.70	21.37	26.84	31.80	46.68	19.50	17.28	16.51	16.66		22.66
TSS (Tons/Day)	19.50	18.96	22.34	24.00	28.65	35.03	63.78	29.12	19.97	20.55	19.71		27.42

Total Industrial Contribution (3)

IPP BOD (Tons/Day)	0.39
IPP TSS (Tons/Day)	0.23

Total Domestic Influent Loading

BOD (Tons/Day)	22.28
TSS (Tons/Day)	27.19

Equations:

- (a) BOD Loading (Tons/Day) = Average Daily Flow (MGD) x Avg BOD (mg/L) x (8.34 lbs/gal) / (2000 lbs/ton)
- (b) TSS Loading (Tons/Day) = Average Daily Flow (MGD) x Avg TSS (mg/L) x (8.34 lbs/gal) / (2000 lbs/ton)

Notes:

- (1) Average Daily Flow = RV12 + RV14 + RV31
- (2) BOD and TSS Concentrations measured at the RVSA Raw Influent Sampler as reported to the NJDEP
- (3) As measured and reported by the RVSA SIU IPP Industrial Loading



2026 Average Daily Flow Report

August, 2026

	2025			2026									Average To Date
Meter #	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	
RV01	1.94	1.84	2.15	2.08	2.37	3.13	2.54	2.24	1.97	2.09	2.36		2.25
RV02	2.84	2.85	3.14	2.97	3.23	4.15	3.50	3.24	3.16	3.16	3.49		3.25
RV03	1.27	1.27	1.55	1.51	1.85	2.39	1.52	1.54	1.47	1.42	1.59		1.58
RV04	0.20	0.19	0.20	0.20	0.26	0.32	0.24	0.24	0.22	0.20	0.21		0.22
RV05	0.21	0.21	0.26	0.26	0.30	0.41	0.27	0.27	0.24	0.25	0.30		0.27
RV06	0.40	0.42	0.48	0.47	0.52	0.67	0.44	0.43	0.39	0.40	0.48		0.47
RV07	0.46	0.46	0.54	0.53	0.58	0.77	0.60	0.55	0.50	0.52	0.60		0.55
RV09	2.51	2.28	2.54	2.53	3.34	4.71	2.82	2.64	2.53	2.40	2.75		2.82
RV10	6.57	6.70	7.60	7.05	8.42	11.67	8.17	7.79	6.97	7.09	8.56		7.87
RV11	10.13	10.02	11.69	11.01	13.04	18.08	11.83	11.64	10.56	10.66	13.07		11.98
RV12	4.57	4.80	5.82	5.38	7.89	8.51	5.71	5.45	4.44	5.50	6.51		5.87
RV13	0.50	0.50	0.53	0.59	0.72	1.00	0.64	0.60	0.52	0.55	0.80		0.63
RV14	15.00	15.04	17.54	16.96	20.95	27.80	18.70	17.38	15.66	16.40	19.48		18.26
RV15	0.60	0.58	0.80	0.70	1.09	1.49	0.82	0.69	0.59	0.81	1.35		0.86
RV16A	19.77	20.02	23.96	22.54	29.04	37.01	24.64	23.11	20.34	22.23	26.41		24.46
RV17	0.45	0.41	0.44	0.41	0.49	0.53	0.43	0.42	0.40	0.42	0.52		0.45
RV18	0.78	0.72	0.80	0.77	0.81	0.92	0.73	0.73	0.69	0.57	0.67		0.75
RV19	0.67	0.30	0.33	0.33	0.35	0.43	0.34	0.34	0.31	0.32	0.37		0.37
RV20	0.66	0.66	0.72	0.67	0.70	0.80	0.63	0.65	0.64	0.62	0.63		0.67
RV27	0.00	0.00	0.76	0.00	0.11	1.98	0.00	0.03	0.00	0.07	0.67		0.33
RV28	0.09	0.00	0.05	0.00	0.06	0.18	0.00	0.02	0.00	0.01	0.40		0.07
RV29	0.89	0.89	1.08	1.08	1.20	1.63	1.24	1.17	1.14	1.15	1.29		1.16
RV30	0.20	0.20	0.22	0.22	0.26	0.31	0.24	0.23	0.22	0.23	0.27		0.24
RV31	0.08	0.10	0.14	0.14	0.15	0.53	0.15	0.13	0.11	0.10	0.13		0.16
RV32	5.04	5.02	5.69	5.35	6.93	8.46	5.88	5.37	4.68	5.72	6.77		5.90



2026 Average Industrial TSS Loading Report

August, 2026

Town	SIU Name	Average Daily TSS Loading (Tons/Day)												Average T/D
		Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	
Clark	Kerry 1	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.004	0.023			0.0028
	Kerry 2	0.009	0.009	0.007	0.003	0.007	0.006	0.006	0.007	0.004	0.003			0.0061
	Kerry 3	0.023	0.018	0.016		0.033	0.027	0.046		0.007	0.024			0.0243
	Kerry 4	0.020	0.021	0.029	0.021	0.008	0.016	0.024	0.014	0.032	0.013			0.0198
Clark Total:														0.053
Kenilworth	B&M Finishers	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000			0.0000
	Kenilworth Anodizing	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000			0.0000
Kenilworth Total:														0.000
Mountainside	American Aluminum	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000			0.0000
Mountainside Total:														0.000
Rahway	Clean Haven													0.0000
	Guest Packaging 02	0.001	0.002	0.003	0.006	0.068	0.010	0.001	0.001	0.000	0.002			0.0094
	Guest Packaging 03	0.001	0.004	0.003	0.003	0.003	0.003	0.001	0.003	0.005	0.017			0.0043
	Merck 007	0.049	0.061	0.084	0.031	0.039	0.029	0.013	0.029	0.008	0.072			0.0415
	Merck 012	0.078	0.139	0.053	0.018	0.139	0.088	0.050	0.083	0.077	0.194			0.0919
	Quala Systems	0.005	0.002	0.005	0.001		0.000	0.002	0.001	0.001	0.001			0.0020
	Sunrise Pharmaceutical		0.001			0.002		0.000						0.0010
	Veolia Water Rahway	0.003	0.002	0.011	0.001	0.001		0.003	0.002	0.018	0.004			0.0050
Rahway Total:														0.155
Roselle Park	Crossfield Products	0.011								0.001	0.000			0.0040
	Kenilworth Corporate Prop	0.012	0.023	0.044	0.003	0.005	0.007	0.003	0.001	0.041	0.048			0.0187
Roselle Park Total:														0.023
Springfield	Valcor Engineering	0.002	0.002	0.007	0.002	0.001	0.002	0.002	0.001	0.004	0.004			0.0027
Springfield Total:														0.003
Woodbridge	BASF 1	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000					0.0001
	BASF 2	0.001	0.000	0.000	0.000	0.000	0.001	0.000	0.000					0.0003
	Gentek Building Products		0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000			0.0000

Note: Municipalities without Significant Industrial Users ("SIU") are excluded from this report.

Town	SIU Name	Average Daily TSS Loading (Tons/Day)												Average
		Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	T/D
Woodbridge Total:													0.000	

Note: Municipalities without Significant Industrial Users ("SIU") are excluded from this report.



2026 Average Industrial BOD Loading Report

August, 2026

Town	SIU Name	Average Daily BOD Loading (Tons/Day)												Average T/D
		Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	
Clark	Kerry 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.024	0.000	0.004			0.0028
	Kerry 2	0.039	0.055	0.112	0.029	0.153	0.058	0.031	0.043	0.035	0.019			0.0574
	Kerry 3	0.090	0.113	0.073		0.193	0.238	0.180		0.055	0.072			0.1268
	Kerry 4	0.063	0.027	0.090	0.089	0.073	0.063	0.154	0.083	0.056	0.064			0.0762
Clark Total:														0.263
Kenilworth	B&M Finishers	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000			0.0000
	Kenilworth Anodizing	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000			0.0000
Kenilworth Total:														0.000
Mountainside	American Aluminum	0.001	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.001			0.0003
Mountainside Total:														0.000
Rahway	Clean Haven													0.0000
	Guest Packaging 02	0.021	0.001	0.007	0.018	0.103	0.029	0.005	0.006	0.008	0.008			0.0206
	Guest Packaging 03	0.004	0.003	0.003	0.012	0.005	0.024	0.006	0.008	0.025	0.038			0.0128
	Merck 007	0.010	0.008	0.009	0.004	0.012	0.016	0.006	0.020	0.006	0.012			0.0103
	Merck 012	0.062	0.048	0.036	0.013	0.065	0.051	0.026	0.044	0.074	0.072			0.0491
	Quala Systems	0.017	0.014	0.018	0.043		0.004	0.007	0.003	0.004	0.001			0.0123
	Sunrise Pharmaceutical		0.007			0.004		0.004						0.0050
	Veolia Water Rahway	0.000	0.006	0.000	0.001	0.001		0.000		0.000	0.002			0.0013
Rahway Total:														0.111
Roselle Park	Crossfield Products	0.002								0.002	0.000			0.0013
	Kenilworth Corporate Prop	0.005	0.005	0.001	0.002	0.003	0.004	0.004	0.002	0.008	0.032			0.0066
Roselle Park Total:														0.008
Springfield	Valcor Engineering	0.002	0.001	0.006	0.004	0.001	0.003	0.003	0.002	0.007	0.004			0.0033
Springfield Total:														0.003
Woodbridge	BASF 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000					0.0000
	BASF 2	0.002	0.000	0.001	0.000	0.000	0.000	0.000	0.000					0.0004
	Gentek Building Products		0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.001			0.0002

Note: Municipalities without Significant Industrial Users ("SIU") are excluded from this report.

Town	SIU Name	Average Daily BOD Loading (Tons/Day)												Average
		Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	T/D
													Woodbridge Total:	0.001

Note: Municipalities without Significant Industrial Users ("SIU") are excluded from this report.