

RAHWAY VALLEY SEWERAGE AUTHORITY
1050 EAST HAZELWOOD AVENUE
RAHWAY, NJ 07065
Phone (732) 388-0868 / Fax (732) 382-0774
NJPDES Permit #0024643

TREATMENT WORKS SEWER CONNECTION APPLICATION
(0 - 2000 GPD)

RVSA # _____

The following sewer connection application form must be completed in lieu of a NJDEP Treatment Works Approval, pursuant to N.J.A.C. 7:14A-22.4.

Owner/Applicant: _____ Telephone: _____

Email Address: _____ Fax: _____

Legal Address: _____ Town: _____

State: _____ Zip Code: _____ County: _____

Project Engineer: _____ Telephone: _____

Email Address: _____ Fax: _____

Legal Address: _____ Town: _____

State: _____ Zip Code: _____ County: _____

Builder: _____ Telephone: _____

Email Address: _____ Fax: _____

Legal Address: _____ Town: _____

State: _____ Zip Code: _____ County: _____

Description of Work: (For residential modification, provide existing and proposed number of bedrooms) _____

Location of Worksite: _____ Town: _____

State: _____ Zip Code: _____ County: _____

Tax Map Lot Number: _____ Block Number: _____

Number and Type of Units (see attached page): _____

Nature of Proposed Discharge: Domestic _____ Commercial _____ Industrial _____

Number of Employees if Commercial or Industrial: _____

Anticipated Design Flow: _____ gpd Infiltration: (none allowed) 0 = 0 gpd
(0 - 2000)

Application Fee of **\$100.00, payable to RVSA**, must be submitted with your application.

Circle one: Cash / Check Name on Check: _____

Check # _____ RVSA Receipt # _____

I certify that no downspouts, sump pumps or other non-contaminated water will be discharged into this connection. I further certify that the forgoing statements made by me are true. I am aware that if any statements made herein are false, I am subject to criminal penalties, which include incarceration.

Signature of Applicant/Owner Date

Signature of Municipality Date

Signature of RVSA Representative Date

New Jersey Department of Environmental Protection Regulation N.J.A.C. 7:14A-23.3
Design Flow Calculation Listing

7:14A-23.3 Projected flow criteria. This is a courtesy copy of this rule. All of the Department's rules are compiled in Title 7 of the New Jersey Administrative Code.

(a) The values specified below are to be used in computing the projected flow to wastewater conveyance and treatment facilities and when making an application for a treatment works approval pursuant to N.J.A.C. 7:14A-22. The specific measurement unit listed for each category shall be used as the basis for the projected flow. No additional provisions for inflow and infiltration are required. For the purposes of design only, other values, proposed by the design engineer, through actual water usage data, may be accepted at the Department's discretion, with an appropriate safety factor. However, all determination concerning whether or not any specific project requires a treatment works approval and/or sewer ban exemption shall be based upon the projected flow criteria established below. These criteria are not mandated to be used by sewerage authorities as a basis for establishing local user fees and/or connection fees.

Type of Establishment	Measurement Unit	Gallons Per Day
Residential Dwellings (single family home, duplex units, townhouses, condominiums, apartments)		
1 bedroom unit	Per Dwelling	150
2 bedroom unit	Per Dwelling	225
3 bedroom unit or larger	Per Dwelling	300
1 bedroom unit (age restricted)	Per Dwelling	110
2 bedroom unit (age restricted)	Per Dwelling	170
3 bedroom unit (age restricted)	Per Dwelling	225
Transit dwelling units		
Hotels	Bedroom	75
Lodging houses and tourist homes	Bedroom	60
Motels and tourist cabins	Bedroom	60
Boarding houses (max. permitted occupancy)	Boarder	50
Camps		
Campground - Mobile rec. vehicle/Tent	Site	100
Parked mobile trailer site	Site	200
Children's camps	Bed	50
Labor camps	Bed	40
Day camps--no meals	Person	15
Restaurants (including washrooms and turnover)		
Average restaurant	Seat	35
Bar/Cocktail lounges	Seat	20
Fast food restaurant	Seat	15
24 hour service restaurant	Seat	50
Curb service/Drive-in restaurant	Car Space	50
Clubs		
Residential	Member	75
Nonresidential	Member	35
Racquet club	(Per Court Per Hour)	80
Bathhouse with shower	Person	25
Bathhouse without shower	Person	10

Design Flow Calculation Listing Cont'd.		
Type of Establishment	Measurement Unit	Gallons Per Day
<i>Institutions</i> (includes staff)		
Hospitals	Bed	175
Assisted living facility	Bed	100
Skilled nursing facility	Bed	75
Other institutions	Bed	125
<i>Schools</i> (includes staff)		
No shower or cafeteria	Student	10
With cafeteria	Student	15
With cafeteria and showers	Student	20
With cafeteria, showers and laboratories	Student	25
Boarding	Student	75
<i>Automobile service stations</i>		
Service bays	Per Filling Position	125
Mini-market	Per Bay	50
	Sq. Ft.	0.100
<i>Miscellaneous</i>		
Office buildings (gross area)	Sq. Ft.	0.100
Stores and shopping centers (gross area)	Sq. Ft.	0.100
Factories/Warehouses (add process wastewater)	Employee	25
Factories/Warehouses with showers, (add process wastewater)	Employee	40
Laundromats	Per Machine	580
Bowling alleys	Alley	200
Picnic Parks (restrooms only)	Person	10
Picnic Parks with showers	Person	15
Fairgrounds (based upon average attendance)	Person	5
Assembly halls	Seat	3
Airports (based on passenger use)	Passenger	3
Churches (worship area only)	Seat	3
Theater (indoor)	Seat	3
Dinner theater	Seat	20
Catering/Banquet Hall	Person	20
Sports stadium	Seat	3
Visitor Center	Visitor	5
Multi-member swimming pool	Person	15

(b) Flow for facilities that have combined uses shall be determined by the summation of all appropriate projected flow values for each use.

(c) The Department recognizes that the table in (a) above may not cover all establishments and facilities, and in particular facilities that require an industrial treatment works approval. In the event that a facility is not covered, the applicant shall propose the projected flow based upon operation of similar facilities or best professional judgment. The Department reserves the right to accept, modify or deny the proposed flow values.